

### Thermostatic mixing valve for solar applications Art. 1561s – 1563s



#### 100% MADE IN ITALY 🛽 🖡

Function Pintossi + C thermostatic mixing valve is designed for use in domestic water as well as heating systems.

The main function is to **maintain constant**, to a set value, **the mixed water temperature**, regardless of any variation of temperature and pressure of hot and cold water supply. The thermostatic mixing valve is equipped with a temperature-sensitive element that detect the temperature of the mixed water. This sensor is directly in contact with the fluid, allowing a high precise measurement of the mixed water and grating and **high speed response** in case of temperature and pressure changes in the inlet hot and cold water.





An **anti-burn function** is provided by the valve, stopping the hot mixed water delivery in case of unexpected interruption of the inlet cold water supply, avoiding potentials burns. Thanks to this and anti-burning function the valve is particular indicated in public buildings like schools and hospitals for

the presence of individuals at risk. This function stays activated only for set water mixed temperatures  $<50^{\circ}$ C, beyond which it's disable.



An **anti-legionella function** allows the an-burn function by-pass, maintaining open the supply of hot water at high temperature, when the knob is set to the maximum opening and the inlet cold water supply is closed.

Thanks to the **high water temperatures allowed**, the valve is suitable for use in solar systems or in standard systems where the incoming hot water can reach high temperatures.

The valve can be installed in single or multiple points of use such as sink, shower, bidet etc. as well as in heating applications. This type of valve is also particularly suitable for use in fixed point mixing systems in underfloor heating systems with radiant soil. In this way, the lukewarm water returning from the radiant panels can be mixed with the water arriving from the hot water production source for heating use, leading to significant economic savings. The valve is suitable for use with drinking water and complies with the provisions of the Ministerial Decree 174/2004.

Product range	Art. 1561s	3/4″	Male thermostatic mixing valve
	Art. 1563s	1/2''	Pipe union thermostatic mixing valve
	Art. 1563s	3/4''	Pipe union thermostatic mixing valve

#### Technical Fluids: Max. g Specifications Max. v

Max. glycol: Max. working temp.: Max. working pressure: Mixed water range: Min cold inlet water temp.: Max hot inlet water temp.: Anti-legionella mixed temp. activation: Stabilità temperatura: Kv: Water or glycol solutions 30% 100°C 10 bar 27°C - 55°C 4°C 100°C >50°C (set max opening) +/- 3°C 1,1

#### Materials

Body: Thermostatic cartridge: Strainer: Gaskets: Wheelhandle: Brass CW617N Plastic Stainless steel EPDM ABS (yellow)

#### Dimensions







PINTOSSI+C S.P.A. | Via Ponte Gandovere, 43 Gussago (BS) Italy | +39 030 3733138 | info@pintossi.it | www.pintossi.it |

1563 3/4"



## Circuit preparation

It's important to verify the systems conditions before proceeding with the installation of the thermostatic mixing valve in the circuit, like temperature and pressure, which must be aligned with those requested in the technical datasheet. Clean the pipes from any metallic debris and scaling. Besides it's important, for a correct functioning of the valve, that the air contained in the system is removed.

Is recommended to inspect the TMV at least once per year to verify it is operating correctly, especially in installations with poor or unknown water quality. For this reason, is recommended the use of strainers or to treat the water with suitable instruments.

The valve may be positioned in any orientation.

# Installation1. Ensure that each pipe ends is aligned with the valve.<br/>2. Connect the hot water supply with the inlet marked HOT.<br/>3. Connect the cold water supply with the inlet marked COLD.<br/>4. Connect mixed water line to outlet marked MIX.<br/>5. Fully tighten the threads with each connection.<br/>6. Set the desired temperature output using the wheelhandle.<br/>7. Turn the wheelhandle to increase or decrease the outlet temperature as needed.

8. Verify the correct mixed water temperature is being achieved.

Temperature				
	MARKING	MIN	RED LINE	MAX
setting	TEMP.	27°C	38°C	55°C



Accessories In order to facilitate servicing and cleaning operations Pintossi + C shutoff cock with swivel nut art.5018 (female thread) or 5553 (male thread) are available as spare part.



It is advisable to install filters (art. 9023) on the inlet water connections, in order to retains impurities and dirt that could compromise the correct functioning of the valve.

Besides in order to prevent unwanted backflows situations it's necessary to install check valves.

Maintenance To ensure the perfect functioning of the thermostatic mixing valve and to prevent a decrease of the flow, it is essential that the internal strainer incorporated in the cartridge, retains its original filtering characteristics. Therefore, it is recommended to check periodically the filter and clean it from dirt. The cleaning of the strainer may be facilitated by installing on the inlet connections of the valve shut off valves to close the flow. The cartridge removal must be done unscrewing the locking nut. After cleaning the cartridge, it must be repositioned inside the valve body following the instruction on the side picture in order not to modify the wheelhandle stroke which directly affects water mixing temperature.



## Fluid characteristics

Reference standard for water treatments in heating systems is Norm UNI 8065:2019 which regulates the parameters that must be observed to avoid scale and corrosion phenomena.

S In order to grant product warranty, the fluid characteristics must comply with the rules in force in the country of relevance or at least present features not less to the ones prescribed by the Norm UNI 8065:2019.

In particular, minimum standards necessary but not sufficient to control are the following:

Fluid aspect:	Limpid		
PH:	Between 7 and 8		
Iron (FE):	< 0,5 mg/kg (< 0,1 mg/kg for steam)		
Copper (CU):	< 0,1 mg/kg (< 0,05 mg/kg for steam)		
Antifreeze:	Passiveted Propylene Glycol		
Conditioning:	as indicated by the producer		

In any case when using antifreeze and conditioning solutions, is required to control and verify the correct compatibility between these substances and the construction materials stated in Pintossi+C technical datasheet.