

 SCHEDA N°
 DATA AGG.

 0162949001
 07/2025

Undersink elbows Art. 4880 – 4882 – 4884 – 4885



100% MADE IN ITALY

Product	Art. 4880	1/2"x1/2"	Shower hose connection 90° elbow			
	Art. 4882	1/2"x10	Undersink 90° elbow with compression fitting			
range	Art. 4884	1/2"x3/8"	Undersink 45° elbow			
	Art. 4885	1/2"x10	Undersink 45° elbow with compression fitting			
Technical	Fluids:		Water			
Technical	Decifications Max working temp.: Max working pressure:		90°C			
specifications			10 bar			
Materials	Body:		Brass CW617N			
Sealing gaskets Flange:		kets:	NBR			
			Stainless steel inox			

Dimensions



ART.	Α	В	С	D	Ε	F
4882	60	20	1/2"	23	50	75



ART.	Α	В	С	D	E
4884	60	1/2"	19	50	3/8"
4885	60	1/2"	22	50	10



PINTOSSI+C S.P.A. | Via Ponte Gandovere, 43 Gussago (BS) Italy | +39 030 3733138 | info@pintossi.it | www.pintossi.it |

2

Installation of The undersink elbow art.4882 is equipped with a hexagon on the the

compression fitting



For a correct installation and sealing, it is important to assemble the various components (olives, gaskets, etc.) following the image shown here, taking care to check the orientation of the gaskets and olives during assembly.

body to allow easy installation and grip with pipe wrench.



Fluid characteristics

Reference standard for water treatments in heating systems is Norm UNI 8065:2019 which regulates the parameters that must be observed to avoid scale and corrosion phenomena. In order to grant product warranty, the fluids characteristics must comply with the rules in force in the country of relevance or at least present features not less to the ones prescribed by the Norm UNI 8065:2019.

In particular, minimum standards necessary but not sufficient to control are the following:

Fluid aspect:	Limpid
PH:	Between 7 and 8
Iron (FE):	< 0,5 mg/kg (< 0,1 mg/kg for steam)
Copper (CU):	< 0,1 mg/kg (< 0,05 mg/kg for steam)
Antifreeze:	Passiveted Propylene Glycol
Conditioning:	as indicated by the producer

In any case when using antifreeze and conditioning solutions, is required to control and verify the correct compatibility between these substances and the construction materials stated in Pintossi+C technical datasheet.